




**Istituto per le Tecnologie
della Costruzione**

Consiglio Nazionale delle Ricerche

Via Lombardia 49 - 20098 San Giuliano Milanese - Italy
tel: +39-02-9806.1 - Telefax: +39-02-98280088
e-mail: info@itc.cnr.it



EOTA Member



www.eota.eu
European Organisation for
Technical Assessment
Organisation Européenne
pour l'évaluation technique

European Technical Assessment - ETA 10/0027 of 20/06/2018

(English language translation; the original version is in Italian)

GENERAL PART

Trade name of the construction product

**“CAPATECT PU LINE STIFERITE CLASS SK”
“CAPATECT PU LINE STIFERITE VV”**

Product family to which the construction product belongs

**PAC 04: THERMAL INSULATION PRODUCTS.
COMPOSITE INSULATING KITS/SYSTEMS.
External Thermal Insulation Composite
System with renderings for the use as
external insulation to the walls of buildings**

Manufacturer

**Stiferite S.p.A.
viale Navigazione Interna, 54
I - 35129 Padova (PD) - Italy**

Manufacturing plant

**Stiferite S.p.A.
viale Navigazione Interna, 54
I - 35129 Padova (PD) - Italy
Caparol Italiana GmbH & Co. KG - Largo
Caparol 1
I - 20080 Vermezzo (MI) - Italy**

Licensee/agent:

This European Technical Assessment contains:

11 pages

This European Technical Assessment is issued in accordance with Regulation (EU) n° 305/2011, on the basis of

**ETAG 004 Edition 2013, used as EAD
(European Assessment Document)**

The European Technical Assessment is issued by ITC-CNR in Italian language. Translations into other languages shall fully correspond to the original issued document and should be identified as such. Communication of this European Technical Assessment, including transmission by electronic means, shall be in full (excepted the confidential Annex(es) referred to above). However, partial reproduction can be made with the written consent of ITC-CNR (issuing Technical Assessment Body). In this case partial reproduction has to be designated as such.

SPECIFIC PARTS

1. TECHNICAL DESCRIPTION OF THE PRODUCT

"CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" (difference between the two alternatives consisting in the insulation product) are designed and installed in accordance with the ETA Holder design and installation instructions, deposited at ITC-CNR.

According to categories envisaged by § 2.2 of ETAG 004 Edition 2013 (ETAG 004 in the following text), used as EAD, the kits "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" are bonded system (required bonded surface: at least 40%) with supplementary mechanical fixings (the fixings are used to provide stability until the adhesive has dried and act as a temporary connection); they comprise the components described in the following Table 1 which are factory-made by the ETA Holder or by his suppliers. The ETA Holder is ultimately responsible for the kits.

1.1 Components of the kits "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV"

The components of the kits are specified by the ETA Holder as follows:

Component	Trade name	Installation information	
		Coverage (kg/m ²)	Thickness (mm)
Adhesive (cement CEM II AL 42.5 R based powder paste requiring addition of 22-24 % of water); particle size: 1.0 mm	"Capatect Klebe und Spachtelmasse 190"	4 - 6	//
Insulation product 1 (PIR panels) (see further description at § 4.1.1)	"Stiferite Class SK"	//	min: 20 mm max: 120 mm
Insulation product 2 (PIR panels) (see further description at § 4.1.2)	"Stiferite VV"	//	min: 20 mm max: 120 mm
Base coat (cement CEM II AL 42.5 R based powder paste requiring addition of 22-24 % of water); particle size: 1.0 mm	"Capatect Klebe und Spachtelmasse 190"	4 - 6 (prepared product)	3 - 4 mm
Reinforcement (glass fibre mesh) (mesh size: 4 x 5 mm)	"Capatect Gewebe 650"	//	//
Key coat (acrylic watery solution)	"Caparol Putzgrund"	250 gr/mq	100 µ
Finishing coat (ready to use paste based on acrylic resin) particle size: 1.5 mm	"Capatect Putz 622 W Silacryl"	2.5 - 3.5 (prepared product)	1.5 ± 0.1 mm
Ancillary materials:			
Base profiles in PVC: U profiles (length 200 cm - different sections)	"Capatect Sockelschienen 6700 Plus"	//	1
Corner profiles in PVC: L- Profiles (length 250 cm - different sections)	"Capatect Gewebe Eckschutz 656/02"	//	1
Anchors in plastic: (one-piece plastic anchors consisting of a collar and a nail) different lengths in relation with thickness of insulation	"Capatect 041"	4-6/m ²	Ø of the collar: 6.0 cm Ø of the nail: 1.25 cm

Tab. 1: Components of the kits

2. SPECIFICATION OF THE INTENDED USE IN ACCORDANCE WITH ETAG 004 USED AS EUROPEAN ASSESSMENT DOCUMENT

"CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" are intended for use as external thermal insulation composite system of buildings' walls and in particular for new and existing buildings whose facades can be made of masonry (bricks, concrete, stones, ...), in concrete cast on site or in prefabricated panels, or can be rendered and coated or uncoated; the substrate may need preparation as described in § 7.2.1 of ETAG 004, used as EAD.

The kit can be used on vertical walls. It can also be used on horizontal or inclined surfaces which are not exposed to precipitation. It is made of non load-bearing construction elements and the installed system does not contribute directly to the stability of the wall on which it is installed, but it can contribute to durability by providing enhanced protection from the effects of weathering. The installed system is not intended to ensure the air tightness of the building structure.

The provisions made in this ETA are based on an assumed intended working life of at least 25 years, provided that the conditions laid down in section 2.2, 2.3, 2.4 of this ETA for the packaging, transport, storage, installation as well as appropriate use, maintenance and repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the manufacturer or by the Assessment Body, but should only be regarded as a mean for choosing the appropriate products in relation to the expected economically reasonable working life of the works.

2.1 Manufacturing

The "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" components shall correspond, as far as their composition and manufacturing process is concerned, to the products subject to the assessment tests. Manufacturing process scheme is deposited with ITC-CNR.

2.2 Installation

2.2.1. General

It is the responsibility of the ETA Holder to guarantee that the information about design and installation of the systems "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" are effectively communicated to the concerned people. These information can be given using reproductions of the respective parts of this European Technical Assessment. Besides, all the data concerning the execution shall be indicated clearly on the packaging and/or the enclosed instruction sheets using one or several illustrations. In any case, it is suitable to comply with national regulations and particularly concerning fire.

Only the components described in clause 1.1 with characteristics in accordance with clause 2 of this ETA can be used for the systems "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV". The requirements given in ETAG 004, used as EAD, chapter 7, have to be considered.

2.2.2. Design

The kits are bonded system with supplementary mechanical fixings. To bond the systems, the minimal bonded surface area and the method of bonding shall comply with characteristics of the systems "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" as well as the national regulations. In any case, the minimal bonded surface shall be at least 40%.

2.2.3. Execution

The recognition and preparation of the substrate as well as the generalities about the execution of the systems "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV", which are fully described in the current version of the ETA Holder Catalogue, shall be carried out in compliance with:

- chapter 7 of the ETAG 004, used as EAD;
- national regulations in effect, if any.

The particularities in execution linked to the method of bonding and the application of the rendering system shall be handled in accordance with ETA Holder prescriptions. In particular it is suitable to comply with the quantities of rendering applied, the thickness regularity and the drying period between 2 layers.

2.3 Packaging, transport and storage

Packaging of the components has to be such that the products are protected from moisture during transport and storage, unless other measures are foreseen by the manufacturer for this purpose and, in case, by ETA Holder specifications.

The components have to be protected against damage.

2.4 Maintenance and repair of the works

It is accepted that the finishing coat shall normally be maintained in order to fully preserve the system's performances.

Maintenance, which is clearly described in the current version of the ETA Holder Catalogue, includes:

- the repairing of localised damaged areas due to accidents,
- the application of various products or paints, possibly after washing or *ad hoc* preparation.

Necessary repairs should be done rapidly.

It is important to be able to carry out maintenance as far as possible using readily available products and equipment, without spoiling appearance.

3. PERFORMANCE OF THE PRODUCT AND REFERENCES TO THE METHODS USED FOR ITS ASSESSMENT

The tests for the assessment of the performances of "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" were carried out according to the tests mentioned in ETAG 004, used as EAD; the performances are valid only if the kit's components are exactly the ones mentioned at § 1 of this ETA.

3.1 Safety in case of fire

3.1.1 Reaction to fire "CAPATECT PU LINE STIFERITE CLASS SK"

The reaction to fire has been determined according with § 5.1.2.1 of ETAG 004.

Euroclass according to the Delegated Regulation (EU) 2016/364:

	Organic content of the rendering system (%)	Flame retardant content of the rendering system (%)	Maximum thickness (mm)	Class
"CAPATECT PU LINE STIFERITE CLASS SK"	base coat: 3.5% finishing coat: 8%	0	120	B – s1, d0

Tab. 2: Reaction to fire

Mounting and fixing

(for all end use applications given in 1.2 of this ETA)

The assessment of reaction to fire is based on tests with a maximum insulation layer thickness of SBI / 120 mm, EN 11925-2 / 60 mm and a maximum insulation material (PIR) density of 34.00 kg/m³, as well as a rendering system with a maximum organic content of 11.5% and a thickness of 5 mm. For the SBI test the system was mounted directly to a calcium silicate substrate (A2-s1, d0) with a minimum density of 815 kg/m³.

The mounting of the specimen was carried out at ITC-CNR Laboratory by the Manufacturer following the specifications given in his ETA Technical Dossier and in his Recommendations, using a single layer of the glass fibre mesh all over the specimen (without overlapping the mesh). The specimen didn't include any joints nor anchors

(anchors have no influence on the test results); the panel edges were rendered, excluding the bottom edge and the top of the specimen.

Extended application

The test results cover arrangements with insulation materials (PIR) of a lower thickness and density, as well as with rendering systems (binder types) with a lower organic content.

3.1.2 Reaction to fire of "CAPATECT PU LINE STIFERITE VV" No Performance Determined

3.2 Hygiene, health and the environment

3.2.1 Water absorption (capillarity test)

The water absorption has been determined in accordance with § 5.1.3.1 of ETAG 004, used as EAD.

Water absorption	after 1 hour		after 24 hours	
	< 1.0 kg/m ²	≥ 1.0 kg/m ²	< 0.5 kg/m ²	≥ 0.5 kg/m ²
Base coat "Capatect Klebe und Spachtelmasse 190"	X	not applicable	X	
Rendering system made of: - base coat "Capatect Klebe und Spachtelmasse 190" - key coat "Caparol Putzgrund" - finishing coat "Capatect Putz W Silacryl" 622	X	not applicable	X	

Tab. 3: Water absorption

3.2.2 Hygrothermal behaviour (heat-rain and heat-cold cycles)

In accordance with the method envisaged in 5.1.3.2.1 ETAG 004, the kit has been applied on rig and the hygrothermal behaviour of the 2 alternatives has been assessed.

None of the following defects occurred:

- blistering or peeling of any paint finishing,
- failure or cracking associated with joints between insulation products boards or profiles fitted with the system,
- detachment of the render,
- cracking allowing water penetration to the insulation layer.

Assessment: the systems "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" are resistant to hygrothermal cycles.

3.2.3 Freeze thaw behaviour

As shown in Table 3 of this ETA, the water absorption of the base coat and of rendering systems is less than 0.5 kg/m² after 24 hours and so the system can be assessed as freeze/thaw resistant without any further testing.

3.2.4 Impact resistance

The tests have been performed on the rig on the 2 alternatives after the hygrothermal cycles, in accordance with § 5.1.3.3 of ETAG 004. The systems were made with one single standard mesh. The resistance of the systems to hard body impacts (3 Joules and 10 Joules) leads to the following use category:

"CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" with Single standard mesh	Use Category I
---	----------------

Tab. 4: Category of impact resistance of "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV"

3.2.5 Water vapour permeability (Resistance to water vapour diffusion)

The water vapour permeability has been determined in accordance with § 5.1.3.4 of ETAG 004.

Water vapour permeability	Acceptance criteria (m)	Equivalent air thickness (m)
Rendering system made of: - insulation "Stiferite CLASS SK" - base coat "Capatect Klebe und Spachtelmasse 190" (3.0 mm) - key coat "Caparol Putzgrund" (100 µ) - finishing coat "Capatect Putz 622 W Silacryl" (1.5 mm)	≤ 2.0	0.476
Rendering system made of: - insulation "Stiferite VV" - base coat "Capatect Klebe und Spachtelmasse 190" (3.0 mm) - key coat "Caparol Putzgrund" (100 µ) - finishing coat "Capatect Putz 622 W Silacryl" (1.5 mm)	≤ 2.0	0.452

Tab. 5: Water vapour permeability

3.2.6 Release of dangerous substances

(in accordance with § 5.1.3.5 of ETAG 004, and with EOTA TR 034)

The external thermal insulation composite system neither contains nor releases the dangerous substances specified in EOTA TR 034 (October 2015).

A written declaration in this respect was made by the manufacturer. In addition to the specific clauses relating to dangerous substances contained in this European Technical Assessment, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the EU Construction Products regulation 305/2011, these requirements need also to be complied with, when and where they apply.

3.3 Safety in use

3.3.1 Bond strength

The bond strength has been determined in accordance with § 5.1.4.1 of ETAG 004.

Bond strength between:	Acceptance criteria
base coat "Capatect Klebe und Spachtelmasse 190" and insulation product "Stiferite CLASS SK" (§ 5.1.4.1.1): - under dry conditions	≥ 0.08 MPa
base coat "Capatect Klebe und Spachtelmasse 190" and insulation product "Stiferite VV" (§ 5.1.4.1.1): - under dry conditions	≥ 0.08 MPa
adhesive "Capatect Klebe und Spachtelmasse 190" and substrate (concrete) (§ 5.1.4.1.2): - under dry conditions - 2 days of water immersion + 2 hours drying - 2 days of water immersion + 7 days drying	≥ 0.25 MPa ≥ 0.08 MPa ≥ 0.25 MPa
adhesive "Capatect Klebe und Spachtelmasse 190" and insulation product "Stiferite CLASS SK" (§ 5.1.4.1.3): - under dry conditions - 2 days of water immersion + 2 hours drying - 2 days of water immersion + 7 days drying	≥ 0.08 MPa ≥ 0.03 MPa ≥ 0.08 MPa
adhesive "Capatect Klebe und Spachtelmasse 190" and insulation product "Stiferite VV" (§ 5.1.4.1.3): - under dry conditions - 2 days of water immersion + 2 hours drying - 2 days of water immersion + 7 days drying	≥ 0.08 MPa ≥ 0.03 MPa ≥ 0.08 MPa

Tab. 6: Bond strength between "Capatect Klebe und Spachtelmasse 190" and different substrates

3.3.2 Fixing strength

In accordance with what envisaged in Table 3 and in § 5.1.4.2 of ETAG 004, being "CAPATECT PU LINE STIFERITE CLASS SK" and "CAPATECT PU LINE STIFERITE VV" a bonded system, the Fixing strength (Displacement test) and Wind load resistance performances were not determined.

3.4 Protection against noise

3.4.1 Airborne sound insulation (ETAG 004 used as EAD, § 5.1.5)
No Performance Determined.

3.5 Energy economy and heat retention

3.5.1 Thermal resistance

The additional thermal resistance provided by the ETICS (R_{ETICS}) to the substrate wall is calculated from the thermal resistance of the insulation product (R_D), determined in accordance with 5.2.6.1, and from the tabulated R_{render} value of the render system (R_{render} is about $0.02 \text{ m}^2\text{K/W}$),

$$R_{ETICS} = R_D + R_{render} \text{ [(m}^2\text{K)/W]}$$

as described in:

- EN ISO 6946: Building components and building elements - Thermal resistance and thermal transmittance - Calculation method.

- EN ISO 10456: Building materials and products - Hygrothermal properties – Tabulated design values and procedures for determining declared and design thermal values.

If the thermal resistance cannot be calculated, it can be measured on the complete ETICS as described in:

EN 1934: "Thermal insulation - Determination of steady state thermal transmission properties - Calibrated and guarded hot box".

The thermal bridges caused by mechanical fixing devices influence the thermal transmittance of the entire wall and shall be taken into account using the following calculation:

$$U_c = U + \Delta U \text{ [W/(m}^2\text{K)]}$$

With:

U_c corrected thermal transmittance of the entire wall, including thermal bridges
 U thermal transmittance of the entire wall, including ETICS, without thermal bridges

$$U = \frac{1}{R_{ETICS} + R_{substrate} + R_{se} + R_{si}}$$

$R_{substrate}$ thermal resistance of the substrate wall [(m²×K)/W]

R_{se} external surface thermal resistance [(m²×K)/W]

R_{si} internal surface thermal resistance [(m²×K)/W]

ΔU correction term of the thermal transmittance for mechanical fixing devices

= $\chi_p \cdot n$ (for anchors) + $\sum \psi_i \cdot \xi_i$ (for profiles)

χ_p point thermal transmittance value of the anchor [W/K]. See Technical Report n°25. If not specified in the anchors ETA, the following values apply:

= 0.002 W/K for anchors with a stainless steel screw with the head covered by plastic material, and for anchors with an air gap at the head of the screw.

= 0.004 W/K for anchors with a galvanized steel screw with the head covered by a plastic material

= 0.008 W/K for all other anchors (worst case)

n number of anchors per m²

ψ_i linear thermal transmittance value of the profile [W/(m²·K)]

ξ_i length of the profile per m²

The influence of thermal bridges can also be calculated as described in: EN ISO 10211: Thermal bridges in building construction - Heat flows and surface temperatures - Detailed calculations.

It shall be calculated according to this standard if there are more than 16 anchors per m² foreseen. The cp-values given by the manufacturer do not apply in this case.

3.6 Sustainable use of natural resources

No Performance Determined.

3.7 Aspects of durability and serviceability

3.7.1 Bond strength after ageing

The bond strength of the system after ageing has been determined following the method envisaged in § 5.1.7.1.1 of ETAG 004, used as EAD.

Bond strength after ageing on the rig	Acceptance criteria
Bond strength between base coat "Capatect Klebe und Spachtelmasse 190" + "Caparol Putzgrund" + finishing coat "Capatect Putz 622 W Silacryl" and insulation "Stiferite CLASS SK"	≥ 0.08 MPa
Bond strength between base coat "Capatect Klebe und Spachtelmasse 190" + "Caparol Putzgrund" + finishing coat "Capatect Putz 622 W Silacryl" and insulation "Stiferite VV"	≥ 0.08 MPa

Tab. 7: Bond strength after ageing

4 Component's characteristics and parameters¹

The tests on components have been carried out in accordance with § 5.2 and to Annex C of ETAG 004, used as EAD, in order to verify the declared values; the results were positive; where the declared values were not given by the Applicant, the value of ETAG 004, used as EAD, have been adopted.

4.1 Insulation product

4.1.1 "Stiferite CLASS SK"

PIR panels with right edges covered with saturated glass felt. Their characteristics are given in the following table.

Descriptions and characteristic	PIR Panels
Reaction to fire (EN 11925-2) thickness: 20 -120 mm density: 35 kg/m ³	Euroclass E (EN 13501-1)
Water absorption by partial immersion (EN 1609) thickness: 100 mm density: 35 kg/m ³	≤ 1 kg/m ²
Water vapour permeability (μ) (EN 12086) thickness: 100 mm	56.00 ± 2
Tensile strength (kPa) (EN 1607)	150
Compression CS(10) kPa (EN 826)	150
Shear strength (EN 12090)	≥ 0.02 N/mm ²
Shear modulus of elasticity (EN 12090)	≥ 1.00 N/mm ²
Conductivity (λ _D)	≤ 0.028 W/mK

¹ The ETA Holder could change, under his own responsibility, some of the suppliers of a component, but only provided that the characteristics and the performances of the new components and the final performances of the system do not change at all. These changes must be fully recorded within the Factory Production Control documents in order to grant full traceability.

(EN 12667) thickness < 80 mm	
Conductivity (λ_D) (EN 12667) thickness \geq 80 mm	≤ 0.026 W/mK
Thermal resistance for the minimum thickness (20 mm) (EN 12667)	0.71 m ² K/W
Thickness (EN 823)	T2 (EN 13165)
Length (EN 822)	1200 \pm 7.5 mm (EN 13165)
Width (EN 822)	600 \pm 5 mm (EN 13165)
Squareness (EN 824)	≤ 6 mm/m (EN 13165)
Flatness (EN 825)	≤ 5 mm (EN 13165)
Surface conditions	Cut surface
Density (EN 1602)	35 \pm 2 kg/m ³
Dimensional stability (23° \pm 2°C, 50 \pm 5% RH) (EN 1603)	≤ 0.01 %
Dimensional stability (70° \pm 2°C , 90 \pm 5% RH for 48 hours) (EN 1604)	thickness \leq 40 mm: ≤ 2 %
	thickness > 40 mm: ≤ 1 %

Tab. 8: Characteristics of Insulation product "Stiferite CLASS SK"

4.1.2 Insulation product "Stiferite VV"

PIR panels with right edges covered with mineral glass felt. Their characteristics are given in the following table.

Descriptions and characteristic	PIR Panels
Reaction to fire (EN 11925-2) thickness: 20 -120 mm density: 44 kg/m ³	Euroclass E (EN 13501-1)
Water absorption by partial immersion (EN 1609) thickness: 40 mm density: 44 kg/m ³	≤ 1 kg/m ²
Water vapour permeability (μ) (EN 12086) thickness: 100 mm	56.00 \pm 2
Tensile strength (kPa) (EN 1607)	200
Compression CS(10) kPa (EN 826)	150
Shear strength (EN 12090)	≥ 0.02 N/mm ²
Shear modulus of elasticity (EN 12090)	≥ 1.00 N/mm ²
Conductivity (λ_D) (EN 12667) thickness < 80 mm	≤ 0.028 W/mK
Conductivity (λ_D) (EN 12667) thickness \geq 80 mm	≤ 0.026 W/mK
Thermal resistance for the minimum thickness (20 mm) (EN 12667)	0.71 m ² K/W
Thickness (EN 823)	T2 (EN 13165)
Length (EN 822)	1200 \pm 7.5 mm (EN 13165)
Width (EN 822)	600 \pm 5 mm (EN 13165)
Squareness (EN 824)	≤ 6 mm/m (EN 13165)
Flatness (EN 825)	≤ 5 mm (EN 13165)
Surface conditions	Cut surface
Density (EN 1602)	44 \pm 2 kg/m ³
Dimensional stability (23° \pm 2°C, 50 \pm 5% RH) (EN 1603)	≤ 0.01 %

Dimensional stability ($70^{\circ} \pm 2^{\circ}\text{C}$, $90 \pm 5\%$ RH for 48 hours) (EN 1604)	thickness ≤ 40 mm: $\leq 2\%$
	thickness > 40 mm: $\leq 1\%$

Tab. 9: Characteristics of Insulation product "Stiferite VV"

4.2 Rendering system

4.2.1 Rendering system (base coat + reinforcement)

The test has been carried out in accordance with § 5.5.4.1 of ETAG 004

Rendering system strain value	mean value of cracks in warp direction (mm)	mean value of cracks in weft direction (mm)
1.0 %	$w \leq 0.10$	$w \leq 0.10$

Tab. 10: Rendering system strip tensile test results (w = crack's width)

4.3 Reinforcement (glass fibre mesh)

The reinforcement is a glass fibre mesh and its characteristics have been verified through the Identification methods envisaged in Annex C of ETAG 004.

4.3.1 Residual strength of reinforcement after ageing:

Strength after ageing	Results	Acceptance criteria
Residual strength after ageing	≥ 20 N/mm	≥ 20 N/mm
Relative residual resistance (% after ageing) of strength in the as delivered state	$\geq 50\%$ of the value at as delivered state	$\geq 50\%$ of the value at as delivered state

Tab. 11: Residual strength after ageing

5 Assessment and Verification of Constancy of Performance (hereinafter AVCP) system applied, with reference to its legal base

According to Decision 97/556/EC² of the European Commission amended by the Decision 001/596/EC, the AVCP (see Annex V to Regulation (EU) 305/2011) given in the following table applies.

<i>Product</i>	<i>Intended use</i>	<i>Level or class (reaction to fire)</i>	<i>System</i>
External thermal insulation composite systems/kits (ETICS) with rendering	in external wall subject to fire regulations	A1 ⁽¹⁾ , A2 ⁽¹⁾ , B ⁽¹⁾ , C ⁽¹⁾	1
		A1 ⁽²⁾ , A2 ⁽²⁾ , B ⁽²⁾ , C ⁽²⁾ , D, E, (A1 to E) ⁽³⁾ , F	2+
	in external wall not subject to fire regulations	any	2+

Tab. 12: AVCP system

⁽¹⁾ Products/materials for which a clearly identifiable stage in the production process results in an improvement of the reaction to fire classification (e.g. an addition of fire retardants or a limiting of organic material).

⁽²⁾ Products/materials not covered by footnote (1).

⁽³⁾ Products/materials that do not require to be tested for reaction to fire (e.g. Products/materials of Classes A1 according to Commission Decision 96/603/EC).

Considering the Euroclass B for the reaction to fire and that no stage in production process has been identified that corresponds to an improvement of the reaction to fire classification, the system of Attestation of Conformity is System 2+ (see Annex V to Regulation (EU) 305/2011 for tasks and responsibilities).

6. Technical details necessary for the implementation of the AVCP system, as provided for in ETAG 004 used EAD

Technical details necessary for the implementation of the AVCP system are laid down in the Control Plan which is deposited at ITC CNR.

For type testing the results of the tests performed as part of the assessment for the European Technical Assessment shall be used unless there are changes in the production line or plant. In such cases the necessary type testing has to be agreed between ITC CNR and the Notified Body.

**Issued in San Giuliano Milanese, Italy on 20/06/2018
by ITC – CNR**

**Prof. Ing. Antonio Occhiuzzi
Head of Institute ITC – CNR**

1912

...

...

...

...

...

...